

Declaration of Conformity

Issued by Manufacturer Hoffman Enclosures, Inc.

2100 Hoffman Way, Anoka, Minnesota 55303-1745, U.S.A.

declare at our sole responsibility, that these devices are designed and constructed according to the fundamental safety and health requirements.

Enclosure Models: A******CT. A******CTC. A******CTCJ A******CTDP.

A*****HCT, A*****HCTB, A*****HCT1R, A*****NGCT

(Bulletin A90CT)

Hoffman Mild Steel Enclosure or Current Transformer **Equipment Description:**

Enclosure Rating: NEMA / UL / cUL Type 3R

Enclosure Certification: UL50, 50E Listed E27525

Vol. 1 File E27525 Sec. 1

and Report

DESCRIPTION

PRODUCT COVERED:

Boxes, junction and pull, rainproof.

MARKING:

Manufacturer's name or "E27525", "Type 3R Enclosure", and also may be marked "Rainproof". Marking on permanent marker or ink-stamped on box.

Applicable Standards: UL 50 Enclosures for Electrical Equipment, Non-

Environmental Considerations

UL 50E Enclosures for Electrical Equipment, Environmental

Considerations

Glin Kampa

cUL to CSA C22.2 No. 94.1 and 94.2

NEMA250 Enclosures for Electrical Equipment (1000 Volts Maximum)

Authorized by:

12<u>/16/2019 (today's date)</u>

Glen Kampa **Date**

Senior Regulatory Engineer

DOC: CERT-00109 C

Subject to Change Without Notice



CERTIFICATE OF COMPLIANCE

Certificate Number 20190805-E27525 Report Reference E27525-19760123

Issue Date 2019-AUGUST-05

Issued to: Hoffman Enclosures Inc

2100 Hoffman Way Anoka MN 55303-1738

This certificate confirms that BOXES, JUNCTION AND PULL representative samples of Boxes, junction and pull, rainproof.

Have been investigated by UL in accordance with the

Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 50, Enclosures for Electrical Equipment.

Additional Information: See the UL Online Certifications Directory at

https://iq.ulprospector.com for additional information.

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

But Infally
Bruce Mahmerholz, Director North American Certification Program

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licenses of UL. For questions, plea



Page 1 of 1