



Declaration of Conformity

Issued by Manufacturer
Hoffman Enclosures, Inc.
2100 Hoffman Way, Anoka, Minnesota 55303-1745, U.S.A.
declare at our sole responsibility, that these devices are designed and constructed according to the fundamental safety and health requirements.

Enclosure Models: ASB**3R, ASB**4R (Bulletin S90B)

Equipment Description: Hoffman Splitter Box, Type 1

Enclosure Rating: CSA Type 1

Enclosure Certification: CSA C22.2 No. 76-14

PRODUCTS

CLASS 4662 02 - WIREWAYS AND BUSWAYS - Splitters

Splitter Boxes in a general-purpose, sheet steel (Type 1) enclosure; Cat. Number Series ASBXX3R and ASBXX4R; containing terminal blocks suitable for copper only 3 or 4 wires, 400 Amp max., 600 Vac max.

Applicable Standards: CAN/CSA C22.2 No. 76-14 – Splitters

CAN/CSA C22.2 No. 40-1989(R2014) - Cutout, Junction, Pull Boxes

Authorized by:

Glin Kampa

<u>5/22/2020</u> (today's date)

Glen Kampa

Date

Senior Regulatory Engineer

DOC: CERT-00269-B

Subject to Change Without Notice





Certificate of Compliance

Certificate: 1408854 Master Contract: 151630 (042184_C_000)

Project: 70177569 Date Issued: 2018-05-01

Issued to: Hoffman Enclosures Inc.

2100 Hoffman Way

Anoka, Minnesota 55303-1745

USA

Attention: Glen Kampa

The products listed below are eligible to bear the CSA Mark shown



Issued by: Frank Gessner
Frank Gessner

PRODUCTS

CLASS 4662 02 - WIREWAYS AND BUSWAYS - Splitters

Splitter Boxes in a general-purpose, sheet steel (Type 1) enclosure; Cat. Number Series ASBXX3R and ASBXX4R; containing terminal blocks suitable for copper only 3 or 4 wires, 400 Amp max., 600 Vac max.

APPLICABLE REQUIREMENTS

CSA C22.2 No. 76-14 - Splitters

CSA C22.2 No. 40-1989 (R2014) - Cutout, Junction and Pull Boxes

DQD 507 Rev. 2016-02-18

Page 1

