

## Declaration of Conformity

Issued by Manufacturer  
Hoffman Enclosures, Inc.  
2100 Hoffman Way, Anoka, Minnesota 55303-1745, U.S.A.  
declare at our sole responsibility, that these devices are designed and constructed according to  
the fundamental safety and health requirements.

**Enclosure Models:** Q\*\*\*\*\*PCD, Q\*\*\*\*\*PCDCC, Q\*\*\*\*\*ABD, Q\*\*\*\*\*ABDCC,  
Q\*\*\*\*\*PCE, Q\*\*\*\*\*PCECC, Q\*\*\*\*\*ABE, Q\*\*\*\*\*ABECC,  
Q\*\*\*\*\*PCI, Q\*\*\*\*\*PCICC, Q\*\*\*\*\*PCIQRR, Q\*\*\*\*\*PCIQRCCR,  
Q\*\*\*\*\*ABI, Q\*\*\*\*\*ABICC (Bulletin Q41)

**Equipment Description:** Hoffman Qline Type D, E, I

**Enclosure Rating :** CSA Type 4, 4X, 6, 12, 13

**Enclosure Certification:** CSA C22.2 No. 14-13

### PRODUCTS

CLASS - C321107 - INDUSTRIAL CONTROL EQUIPMENT-Miscellaneous Apparatus

Industrial control QLINE enclosures, Type D, E and I Series, polymeric, CSA Type 4, 4X, 6, 12, 13.

**Applicable Standards:** CAN/CSA C22.2 No. 14-13 – Industrial Control Equipment  
CAN/CSA C22.2 No. 94-M91(R2001) – Special Purpose Enclosures  
CAN/CSA C22.2 No. 0.17-00 – Evaluation Of Properties of Polymeric  
Materials

Authorized by:



5/22/2020 (today's date)

**Glen Kampa**

**Date**

Senior Regulatory Engineer

Subject to Change Without Notice

DOC: CERT-00266-B



# Certificate of Compliance

Certificate: 1619917 (042186\_C\_000)

Master Contract: 151630

Project: 70177567

Date Issued: 2018-04-13

Issued to: Hoffman Enclosures Inc.  
2100 Hoffman Way  
Anoka, Minnesota 55303-1745  
USA  
Attention: Glen Kampa

*The products listed below are eligible to bear the CSA Mark shown*



Issued by: *Sze-Oi (Patrick) Ma*  
Sze-Oi (Patrick) Ma

## PRODUCTS

CLASS - C321107 - INDUSTRIAL CONTROL EQUIPMENT-Miscellaneous Apparatus

Industrial control QLINE enclosures, Type D, E and I Series, polymeric, CSA Type 4, 4X, 6, 12, 13.

## APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 14-13 - Industrial Control Equipment  
CAN/CSA-C22.2 No. 94 -M91 - Special Purpose Enclosures  
CAN/CSA-C22.2 No. 0.17-00 - Evaluation of Properties of Polymeric Materials

## MARKINGS

The manufacturer is required to apply the following markings:

- Products shall be marked with the markings specified by the particular product standard.
- Products certified for Canada shall have all Caution and Warning markings in both English and French.

Additional bilingual markings not covered by the product standard(s) may be required by the Authorities Having Jurisdiction. It is the responsibility of the manufacturer to provide and apply these additional markings, where



Certificate: 1619917

Master Contract: 151630

Project: 70177567

Date Issued: 2018-04-27

---

applicable, in accordance with the requirements of those authorities.

Manufacturer's name, type number, CSA environmental rating, CSA Monogram or CSA Monogram with NRTL/C Indicator, appear on an adhesive label affixed to the inside of enclosure. See Ill 1.

The following cautions also appear:

"CAUTION - NONMETALLIC ENCLOSURE DOES NOT PROVIDE GROUNDING BETWEEN CONDUIT CONNECTIONS, USE GROUNDING TYPE BUSHING AND JUMPER WIRES."

"TO MAINTAIN THE ENVIRONMENTAL RATING OF THIS ENCLOSURE, INSTALL IN ANY OPENINGS ONLY LISTED OR RECOGNIZED CONDUIT HUBS OR CONTROL DEVICES WITH THE SAME RATING AS THE ENCLOSURE, IN COMPLIANCE WITH THE INSTALLATION INSTRUCTIONS OF THE DEVICE" or equivalent wording.