

Article 2700172 from revision 00
 Designation IB IL 24 DO8/HD-PAC

Device category 3 - electrical article

Prediction done by: pypw02

				based on	Environmental condition	MTTF in h	MTTF in a	failure rate in FIT (λ basis)
at	25	°C with	21,00 % duty cycle	Telcordia	GB, GC - Ground Benign, Controlled	10519008	1200,8	
at	40	°C with	34,25 % duty cycle	Telcordia	GB, GC - Ground Benign, Controlled	3228060	368,5	
at		°C with	% duty cycle		GB, GC - Ground Benign, Controlled	-	-	
at		°C with	% duty cycle			-	-	
at		°C with	% duty cycle			-	-	
at		°C with	% duty cycle			-	-	