

Article 2700173 from revision 00
 Designation IB IL 24 DI 8 / HD-PAC

Device category 3 - electrical article

Prediction done by: pypw02

				based on	Environmental condition	MTTF in h	MTTF in a	failure rate in FIT (λ basis)
at	25	°C with	21,00 % duty cycle	Telcordia	GB, GC - Ground Benign, Controlled	11147100	1272,5	
at	40	°C with	34,25 % duty cycle	Telcordia	GB, GC - Ground Benign, Controlled	3800964	433,9	
at	55	°C with	100,00 % duty cycle	Telcordia	GB, GC - Ground Benign, Controlled	641232	73,2	
at		°C with	% duty cycle			-	-	
at		°C with	% duty cycle			-	-	
at		°C with	% duty cycle			-	-	