

Article 2701559 from revision 02
 Designation AXL F PSDI8/4 1F

Device category 3 - electrical article

Prediction done by: pyhf01

				based on	Environmental condition	MTTF in h	MTTF in a	failure rate in FIT (λ basis)
at	25	°C with	21,00 % duty cycle	SN 29500	GB, GC - Ground Benign, Controlled	4034128	460,52	247,88503
at	40	°C with	34,25 % duty cycle	SN 29500	GB, GC - Ground Benign, Controlled	1728700	197,34	578,46927
at	60	°C with	100,00 % duty cycle	SN 29500	GB, GC - Ground Benign, Controlled	289283	33,02	3456,82678
at		°C with	% duty cycle			-	-	
at		°C with	% duty cycle			-	-	
at		°C with	% duty cycle			-	-	