

Article 2701560 from revision 02
 Designation AXL F PSDO8/3 1F

Device category 3 - electrical article

Prediction done by: pyhf01

				based on	Environmental condition	MTTF in h	MTTF in a	failure rate in FIT (λ basis)
at	25	°C with	21,00 % duty cycle	SN 29500	GB, GC - Ground Benign, Controlled	2773313	316,59	360,579587
at	40	°C with	34,25 % duty cycle	SN 29500	GB, GC - Ground Benign, Controlled	1162307	132,68	860,357756
at	60	°C with	100,00 % duty cycle	SN 29500	GB, GC - Ground Benign, Controlled	192030	21,92	5207,527742
at		°C with	% duty cycle			-	-	
at		°C with	% duty cycle			-	-	
at		°C with	% duty cycle			-	-	