

The given failure rates refer to more than one article.
For the valid articles please refer to the article list.

Device category 3 - electrical article

Prediction done by: pyff02
Prediction date: 2015-11-16

			based on	User Mode	Environmental condition	MTTF in h	MTTF in a	failure rate in FIT (λ basis)
at	25 °C with	21,00 % duty cycle	SN 29500		GB, GC - Ground Benign, Controlled	26371488,14	3010,44	37,919741
at	40 °C with	34,25 % duty cycle	SN 29500		GB, GC - Ground Benign, Controlled	23026508,48	2628,6	43,428208
at	60 °C with	100,00 % duty cycle	SN 29500		GB, GC - Ground Benign, Controlled	10591677,48	1209,1	94,413751
at	70 °C with	100,00 % duty cycle	SN 29500		GB, GC - Ground Benign, Controlled	9270797,02	1058,31	107,865591

