

The given failure rates refer to more than one article.
For the valid articles please refer to the article list.

Device category 3 - electrical article

Prediction done by: pyff02

				based on	Environmental condition	MTTF in h	MTTF in a	failure rate in FIT (λ basis)
at	25	°C with	21,00	SN 29500	GB, GC - Ground Benign, Controlled	18775691,6	2143,34	53,260355
at	40	°C with	34,25	SN 29500	GB, GC - Ground Benign, Controlled	9250878,65	1056,04	108,09784
at	60	°C with	100,00	SN 29500	GB, GC - Ground Benign, Controlled	1852559	211,48	539,793874
at	70	°C with	100,00	SN 29500	GB, GC - Ground Benign, Controlled	1300222,81	148,43	769,09895
at		°C with				-	-	
at		°C with				-	-	

