

Article

2902995

 from revision

00

 Designation

UNO-PS/1AC/48DC/60W

Device category 3 - electrical article

Prediction done by: psba02

				based on	Environmental condition	MTTF in h	MTTF in a	failure rate in FIT (λ basis)			
at	<table border="1" style="display: inline-table; border-collapse: collapse;"><tr><td style="width: 30px;">40</td></tr></table>	40	°C with	<table border="1" style="display: inline-table; border-collapse: collapse;"><tr><td style="width: 50px;">100,00</td></tr></table>	100,00	% duty cycle	SN 29500	GB, GC - Ground Benign, Controlled	1138502	129,97	878,347
40											
100,00											
at		°C with		% duty cycle			-	-			
at		°C with		% duty cycle			-	-			
at		°C with		% duty cycle			-	-			
at		°C with		% duty cycle			-	-			
at		°C with		% duty cycle			-	-			