

Article

2902997

 from revision

00

 Designation

UNO-PS/1AC/12DC/100W

Device category 3 - electrical article

Prediction done by: psba02

				based on	Environmental condition	MTTF in h	MTTF in a	failure rate in FIT (λ basis)
at	40	°C with	100,00 % duty cycle	SN 29500	GB, GC - Ground Benign, Controlled	506868	57,86	1972,899
at		°C with	% duty cycle			-	-	
at		°C with	% duty cycle			-	-	
at		°C with	% duty cycle			-	-	
at		°C with	% duty cycle			-	-	
at		°C with	% duty cycle			-	-	