

Reliability Prediction Assessment

 Article
 2903000
 from revision
 00

 Designation
 UNO-PS/1AC/15DC/30W

Device category 3 - electronical article

Prediction done by: ps	ba02
------------------------	------

at	40	°C with	100,00	% duty cycle
at		°C with		% duty cycle
at	\neg	°C with		% duty cycle
at		°C with		% duty cycle
at		°C with		% duty cycle
at		°C with		% duty cycle

based o	n
SN 2950	00

Environmental condition		
GB, GC - Ground Benign, Controlled		

MTTF in h	_
911388	
-	
-	
=	
=	
	16

MTTF in a
104,04
-
-
-
2 -
1-

