

Article

2903002

 from revision

00

 Designation

UNO-PS/1AC/15DC/100W

Device category 3 - electrical article

Prediction done by: psba02

				based on	Environmental condition	MTTF in h	MTTF in a	failure rate in FIT (λ basis)
at	40	°C with	100,00	SN 29500	GB, GC - Ground Benign, Controlled	727380	83,03	1374,797
at		°C with				-	-	
at		°C with				-	-	
at		°C with				-	-	
at		°C with				-	-	
at		°C with				-	-	