

Article from revision
 Description

Device category 3 - electrical article

Prediction done by: pybf04
 Prediction date: 2015-07-01

			based on	User Mode	Environmental condition	MTTF in h	MTTF in a	failure rate in FIT (λ basis)
at	25 °C with	21,00 % duty cycle	SN 29500		GB, GC - Ground Benign, Controlled	7299270,07	833,25	137
at	40 °C with	34,25 % duty cycle	SN 29500		GB, GC - Ground Benign, Controlled	3412969,28	389,61	293
at	50 °C with	100,00 % duty cycle	SN 29500		GB, GC - Ground Benign, Controlled	967117,99	110,4	1034
at	65 °C with	100,00 % duty cycle	SN 29500		GB, GC - Ground Benign, Controlled	587544,07	67,07	1702