

Reliability Prediction Assessment

 Article
 2966508
 from revision
 06

 Description
 PLC-ESK GY

Device category 3 - electronical article

Prediction done by:	pykp03
---------------------	--------

at	25	°C with	21,00	% duty cycle
at	40	°C with	34,25	% duty cycle
at	40	°C with	100,00	% duty cycle
at		°C with		% duty cycle
at		°C with		% duty cycle
at		°C with		% duty cycle

based on	
SN 29500	

Environmental condition
GB, GC - Ground Benign, Controlled

MTTF in a
.=
-
13430,03
-
-
-

failure rate in FIT (λ basis)
8,5