

# CERTIFICATE

## (1) EU-Type Examination

(2) **Component intended for use on/in equipment or protective systems intended for use in potentially explosive atmospheres - Directive 2014/34/EU**

(3) EU-Type Examination Certificate Number: **KEMA 00ATEX2052 U** Issue Number: **6**

(4) Product: **Terminal Blocks  
ST 2,5; ST 2,5-TWIN; ST 2,5-QUATTRO and STTB 2,5(-PV)  
Protective conductor terminal blocks  
ST 2,5-PE; ST 2,5-TWIN-PE; ST 2,5-QUATTRO-PE and  
STTB 2,5-PE**

(5) Manufacturer: **PHOENIX CONTACT GmbH & Co. KG**

(6) Address: **Flachsmarktstrasse 8, 32825 Blomberg, Germany**

(7) This product and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

(8) DEKRA Certification B.V., Notified Body number 0344 in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential test report number NL/KEM/ExTR06.0053/05.

(9) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

**EN IEC 60079-0 : 2018**

**EN 60079-7 : 2015 + A1 : 2018**

(10) The sign "U" is placed after the certificate number. It indicates that this certificate must not be mistaken for a certificate intended for an equipment or protective system. This partial certification may be used as a basis for certification of an equipment or protective system.

(11) This EU-Type Examination Certificate relates only to the design and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by this certificate.

(12) The marking of the product shall include the following:



**II 2 GD Ex eb IIC Gb**

Date of certification: 27 February 2020

DEKRA Certification B.V.

L.G. van Schie  
Certification Manager

Page 1/3



© Integral publication of this certificate and adjoining reports is allowed. This Certificate may only be reproduced in its entirety and without any change.

DEKRA Certification B.V. Meander 1051, 6825 MJ Arnhem P.O. Box 5185, 6802 ED Arnhem The Netherlands  
T +31 88 96 83000 F +31 88 96 83100 [www.dekra-product-safety.com](http://www.dekra-product-safety.com) Registered Arnhem 09085396

(13) **SCHEDULE**

(14) **to EU-Type Examination Certificate KEMA 00ATEX2052 U**

Issue 6

(15) **Description**

Terminal Blocks (all colors) ST 2,5; ST 2,5-TWIN; ST 2,5-QUATTRO; STTB 2,5(-PV) as well as Protective Conductor Terminal Blocks Types ST 2,5-PE; ST 2,5-TWIN-PE; ST 2,5-QUATTRO-PE; STTB 2,5-PE with accessories are intended for the connection of copper conductors in enclosures fulfilling the degree of protection which is required by the applied type of protection for the end-application. The Protective Conductor Terminal Blocks are intended for installation on mounting rails type NS 35 according to EN 60715-TH 35.

Operating temperature range -60 °C to +110 °C.

**Electrical data**

See Annex 1 to Report No. NL/KEM/ExTR06.0053/05 for electrical data and nomenclature.

**Installation instructions**

The instructions provided with the product shall be followed in detail to assure safe operation.

(16) **Report Number**

No. NL/KEM/ExTR06.0053/05.

(17) **Schedule of Limitations**

1. The Terminal Blocks and Protective Conductor Terminal Blocks shall be mounted in a certified enclosure that meets the requirements of an approved type of protection as specified in EN 60079-0 clause 1, with a degree of protection at least as required for Ex e. For combustible dust these enclosures must satisfy the requirements according to EN 60079-0 and EN 60079-31.
2. When assembling with other certified series and sizes and using the associated accessories, the required creepage distances and clearances have to be observed.
3. The installation instruction of the manufacturer shall be followed e.g. for the use of cover, jumpers, end brackets. The data regarding current and associated temperature rise shall be used as guideline for the given conductor cross sections. The cross section has an influence on the temperature rise which shall be assessed in the end application.
4. If the Terminal Blocks and Protective Conductor Terminal Blocks are used in electrical apparatus of temperature classes T1 up to T5, the highest temperature of the insulating material shall not exceed the maximum value of the operating temperature range.
5. If the Terminal Blocks and Protective Conductor Terminal Blocks are used in electrical apparatus of temperature classes T6 the permissible ambient temperature range is  $-60\text{ °C} < T_{amb} < +40\text{ °C}$ .

(18) **Essential Health and Safety Requirements**

Covered by the standards listed at item (9).

(19) **Test documentation**

As listed in Report No. NL/KEM/ExTR06.0053/05.

(13) **SCHEDULE**

(14) **to EU-Type Examination Certificate KEMA 00ATEX2052 U**

**Issue 6**

(20) **Certificate history**

Issue 1 - 200354700	Initial certificate.
Issue 2 - 210073500	Assessment to recent edition of standards, operating temperature range changed.
Issue 3 - 211801500	Assessment to recent edition of standards, plastic materials bridges changed.
Issue 4 - 215216600	Assessment to recent edition of standards, operating temperature range changed.
Issue 5 - 219710400	Assessment to recent editions of the standards, small mechanical change.
Issue 6 - 224265600	Addition alternative plastic material bridges.