

INSTALLATION INSTRUCTIONS & CONDITIONS FOR SAFE USE



II 2 GD

Ex eb IIC Gb

Modular TERMINAL Blocks: W- Series
DEMINO 14 ATEXT330 U
IECEX ULD 14.0005U
Notified Body No. Of Ex - QA: 0344
Label print on package unit: 0344
UL21UKEX2114U
Approved Body No. of UK Ex - QA: xxxx
(see product marking)

Standards:

EN IEC 60079-0:2018 and EN IEC 60079-7:2015 A1:2018 IEC 60079-0: 7th Edition and IEC 60079-7: 5.1th Edition

Modular Terminal Blocks: WDU/WPE

Version: WDU 50N * Order No

1820840000

in conjunction with: WPE 50N* Order No

1846040000

Accessories: Type Order No
End bracket WEW 35/1* 1059000000
Terminal rail TS 35/... acc.to DIN EN 60715

Cross-connection Screwable* Order No

WQV 50N/2 1834060000 WQV 50N/3 1834070000 WQV 50N/4 1834080000

Insulation material:

Type Wemid
 Tracking resistance (A) to IEC 60112 CTI ≥ 600
 Flammability class to UL 94 V0

Operating temperature range
 Ambient temperature range
 Go°C...+40°C (for T6 applications)
 Ambient temperature range
 Go°C...+70°C (for T4 applications)

^{*} in all colours and optional with hexagon and six lobe drive



Technical data according to IEC/EN 60079-7 (increased safety "eb"):


	WDU 50N	WPE 50N
- Rated voltage	690 V	
- Rated current	126 A / ΔT 40 K	
- Temperature rise with rated current	27 K / 126 A	
- Rated current with WQV	126 A / ΔT 40 K	
- Contact resistance with rated conductor, 50 mm²	0,15 mΩ	0,19 mΩ
- Rated conductor cross section	50 mm ²	50 mm ²
- Conductor cross section solid	5,26 - 16 mm²	5,26 - 16 mm ²
- Conductor cross section stranded	5,26 - 70 mm ²	5,26 - 70 mm ²
- Conductor cross section flexible	5,26 - 50 mm ²	5,26 - 50 mm ²
- cross section, American Wire Gauge	10 - 0 AWG	10 - 0 AWG
- 2 conductors with same cross-section	6 - 16 mm ²	
- Tightening torque range terminal screw	3,5 - 6,0 Nm	4,0 - 6,0 Nm
- Tightening torque range fixing screw		3,0 - 4,0 Nm
- Tightening torque range for WQV	2,5 - 5,0 Nm	
- Stripping length	24 mm	24 mm

IECEx / ATEX / UKCA Terminal and Cross-Connector Arrangements:

Max voltage data according to IEC/EN 60079-7 in conjunction with protective conductor terminal blocks of the WPE-Series, (increased safety "eb"):

Application Case

- A Continuous
- B Adjacent
- D Intermediate bridging one or more unconnected terminals
- E Next to a protective conductor terminal (earth) without a partition plate



Information for further cross-connector arrangements will be provided on request.

Note:

If smaller cross sections than the rated cross section are used, the belonging lower current has to be laid down in the IECEx/EC-Type Examination Certificate of the complete apparatus.

Mounting instructions:

The WDU/WPE series is suitable for application in enclosures in atmospheres with flammable gases or combustible dust. For use in flammable gases these enclosures must satisfy the requirements according to IEC/EN60079-0 and IEC/EN60079-7. For use in combustible dust these enclosures must satisfy the requirements according to IEC/EN60079-0 and IEC/EN60079-31.

Regarding the use of accessories the instructions of the manufacturer must be followed.



Schedule of Limitations:

The WDU/WPE terminals are suitable for use in enclosures in atmospheres with flammable gases or combustible dust. For flammable gases these enclosures must satisfy the requirements according to IEC/EN60079-0 and IEC/EN60079-7. For combustible dust the enclosure must satisfy the requirements according to IEC/EN60079-0 and IEC/EN60079-31.

The terminal blocks shall be placed inside a suitable IECEx/ATEX/UKCA certified IP54 enclosure for gas atmosphere. For dust atmosphere the terminal blocks shall be mounted inside a suitable IECEx/ATEX/UKCA certified certified 't' enclosure (IEC/EN60079-31).

Under normal operating conditions the temperature rise of the terminal blocks is maximum 40 K, measured at the maximum permitted rated current. Due to the above mentioned, the terminal blocks may be used in apparatus of temperature classes T6..T1 as long as the terminal block ambient temperature range is not exceeded. No part of terminal block must exceed 110 °C under any condition.

T6 (- 60°C ... +40 °C) T5 (- 60°C ... +55 °C) T4 (- 60°C ... +70 °C)

When using the type WDU/WPE especially with other terminal blocks series or sizes or accessories the requirements for clearance and creepage distances according to IEC/EN60079-7 must be observed. Regarding the use of covers, cross-connectors and end brackets the instructions of the manufacturer must be followed.

For cross connection accessories, current rating, resistance across the terminal and torque values please refer to the table under "technical data" above.

The terminal can be used with either one or two wires into either side of the terminal. When two wires are used they must be of the same type, and of equal sizes. No other wire sizes or types than the ones specified in instructions must be used. The terminal blocks must either be mounted next to another block of the same type and size or with an end plate.

If smaller conductor cross sections than the rated conductor cross sections are used, then the corresponding lower current shall be stated in the Certificate of the complete apparatus.

Unused terminals shall be tightened.

Essential Health and Safety Requirements:

Concerning ESRs this Schedule verifies compliance with the Annex II of ATEX / Schedule 1 of UKCA directive and Equipment and Protective Systems Intended for Use in Potentially Explosive Atmospheres Regulations 2016 only. By placing the product on the market, the manufacturer declares compliance with other relevant Directives, and all other safety related requirements including those of Annex II / Schedule 1 of these Directives.